UPPER TRISHULI-1 HEP (216MW)

Client	**Nepal Water and Energy Development Company Private Limited**
Owner's Engineer	**Tractebel Engineering GmbH / Jade Consult**

REVIEW NOTE

Contractor	**Doosan Heavy Industries & Construction Co., Ltd.**		
Title of the Document	Excavation and Support Drawings of Tailrace Outlet Gate Chamber, sheets 1-2		
Document No.	UT1-C-080-CVL-DG-59001	Revision	0A
Date of Documents	11.02.2022	Received Date	13.02.2022
Transmittal Form No.	UT1-HEP-DHI-D-0154		
Previous Review Date/Status	N/A	Prev. Review Note No.	N/A
Review Note No.	**RN-0098**	**Present Review Date**	**26.03.2022**
		Present Review Status	**AN**

A: Approved AN: Approved as Noted RR: Returned for Resubmission FI: For Information, only

Respective reference drawings of the detailed design of the Tailrace Outlet Gate Chamber itself shall be mentioned on the documents under this review.

The mentioned reference drawing doc. ref. UT1-C-000-CVL-DG-40001 "Detail design drawing of excavation and support for underground cavern" is not relevant for the document under this revision.

The final approval of the document under this revision is subject of the approved detailed design of the Tailrace Outlet Gate Chamber.

The detailed design of the Tailrace Outlet Gate Chamber has not been submitted yet by the contractor.

DISCLAIMER

Any approval will not release the Contractor from any of his obligations under the Contract.

Sebastian Beck